

Technical Service Bulletin

11 July 2000

Altronic Research Inc.

P.O. Box 249

Yellville, AR 72687

Tel: 870-449-4093

Fax: 870-449-6000

Subject: Control Circuit Breaker Operation

The magnetic circuit breaker that protects the control transformer will not function as a switch. If power is applied and the breaker is actuated to the closed position, it will immediately trip.

In the event this breaker is tripped, the following procedure may be utilized as corrective action:

1. Turn off the primary power disconnect.
2. Reset the breaker to the closed position.
3. Turn the primary power back on.

This procedure should be repeated any time the control breaker is tripped.

The breaker is installed as a protective device and is not intended as a switch.